



Florida Department of Transportation

CHARLIE CRIST
GOVERNOR

1109 South Marion Avenue
Lake City, Florida 32025

STEPHANIE C. KOPELOUSOS
SECRETARY

October 25, 2010

To: Prospective Bidders & Plan Holders

**Addendum No.: 2, E2O97, Financial Project # 42556925201
Roof Replacement – Perry Maintenance Administration Building in Perry,
Florida**

Questions and Answers:

What is the color or finish of the metal roof to be? On page 4 you ask for Shasta White on page 7 you ask for a Satin or Galvalume finish, can you please clarify this.

ANSWER: The metal roof finish shall be a Shasta White Kynar 500 Fluoropolymer coating. The reference to Galvalume satin finish is for an unfinished metal which does not apply to this project.

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. The bidder is required to acknowledge the addendum in the space provided on the proposal.

Company Name

Date

Signature

Thanks,

Patsy Elkins, CPPB
Contracts Coordinator
Phone: 386-758-3703
Fax: 386-758-3791